

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY
Log No. 115461
Permit No. _____
Basin 089

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67803 ✓

1 OWNER LINDA MANZ
MAILING ADDRESS 3930 TRAVEL WAY
CARSON CITY, NV 89705

ADDRESS AT WELL LOCATION 3930 TRAVEL WAY
CARSON CITY, NV 89705
Subdivision Name: _____ County: Washoe

2 LOCATION SE 1/4 SW 1/4 Sec 6 T 16N R 20 E
PERMIT/WAIVER No. 050-481-36 ✓
Issued by Water Resources Parcel No.

Latitude 39.27502°N UTM E NAD 27
Longitude 119.78281°W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? YES
If yes, what is replacement well NOI? 67802
Is there an existing well log? NO
If yes, what is NDWR well log #? unknown

4 EXISTING WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	75

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
FACTORY SAW CUT	3X3/32	55 feet	75 feet

Additional Perforations:

Type of perforator used:	From	To	Number of perfs per linear foot
MILLS KNIFE	45 feet	58 feet	4

5 WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. _____ P.S.I. _____
Water temperature COLD °F Quality POOR

8 WELL PLUGGING MATERIALS

From	To	Material Used	Neat Cement	Bentonite Grout
0 feet	75 feet	NEAT CEMENT	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured	<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

6 Additional Notes or Comments

**PULLED OUT PUMP PLACED TREEMIE PIPE TO BOTTOM
PUMP WITH NEAT CEMENT TO SURFACE**

*Original log unknown
Replacement well drilled
under log # 115469*

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 07/23/2012
Date Completed 07/23/2012

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548 ✓
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905 ✓
Signed Michael P. [Signature]
By driller performing actual drilling on site or contractor
Date 07/28/2012 ✓

State Use 39.275110°N NAD27
119.781792°W

USE ADDITIONAL SHEETS IF NECESSARY