STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115488
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67875

1. OWNER Kenneth & Jennifer Fisher
MAILING ADDRESS PO Box 1872 Winnemucc, NV

ADDRESS AT WELL LOCATION 4270 Cessna
Winnemucca, NV
Subdivision Name: Airport Estates *County:* Humboldt

2. LOCATION NE ¼ NE ¼ Sec23T35N/ R37E
PERMIT/WAIVER NO. N/A 014-084-04
Issued by Water Resources Parcel. No.

Latitude 40°53.871 UTM E ☐ NAD 27
Longitude 117°46.784 N ☒ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	5	5
Clay		5	15	10
Sand/gravel		15	50	35
Clay		50	60	10
Sand/gravel		60	80	20
Clay		80	110	30
Sand/gravel	X	110	150	40
Clay		150	180	30
Course sand/gravel	X	180	200	20

RECEIVED 2012 JAN 30 AM 11:41 STATE ENGINEERS OFFICE

Date started: December 5, 20 11
Date completed: December 8, 20 11

9. *WELL CONSTRUCTION*
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	200 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	200

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 050
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 55 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☒ Yes ☐ No 50 to 55 ☐ Pumped ☒ Poured
Type:

7. *Water Level*
Static water level: 85 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Fair

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	140	16
	40.897946°N	NAD27
	117.7787169°W	Decl Deg

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the *State Contractor's Board* 021467
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2083
Signed Fred Anderson Drilling Inc.
By driller performing actual drilling on site or contractor
Date December 12.2011