WP R-684

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115489
Permit No.
Basin 29

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67261

1. OWNER ~~ATSD COMPANY, LLC~~ L BAR NEVADA, LLC
MAILING ADDRESS 5245 Vista Blvd F3-327
Sparks NV 89436

ADDRESS AT WELL LOCATION N/A
UNIONVILLE NV 89418
Subdivision Name: ~~PARCEL OF LAND~~ County: preshing

2. LOCATION SW ¼ SE ¼ Sec 27 T 30 N/S R 36 E
PERMIT/WAIVER No. R-684 (Issued by Water Resources) 12-300-13 (Parcel No.)

Latitude N40°26'11.2" Longitude W.117°55'58.6
UTM E 4223606 N 4476402 ☐ NAD 27 ■ NAD 83/WGS 84

3. WORKED PERFORMED
■ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
■ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ■ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	15	15
SANDS GRAVELS		15	35	20
VOLCANICS		35	120	85
HARD ROCK		120	143	23

Date started: 8-13, 20 11
Date completed: 9-3, 20 11

7. Water Level
Static water level: 72 feet below land surface
Artesian Flow: N/A G.P.M. 1 P.S.I.
Water Temperature: COLD °F
Quality: FARE

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ■ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
120 PST		
2000 CFMS 1		4 HRS

9. WELL CONSTRUCTION
Depth Drilled 143 Feet Depth Cased ~~145~~ 143 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	143 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12	.188	+2	6
6	4.06	.316	6	143

Perforations:
Type of perforation FACTORY CUT
Size of perforation CL 6"SDR21 SCREEN.032
From 63 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ■ Yes ☐ No
■ Neat Cement 0 to 6 ■ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
■ ≥30% Bentonite Grout 6 to 50 ■ Pumped ☐ Poured

Gravel Pack: ■ Yes ☐ No 50 to 143 ☐ Pumped ■ Poured
Type: 3/8 GRAVEL
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name INDUSTRIAL DRILLING, INC. (Contractor)
Address 5245 VISTA BLVD, F3-327 (Contractor)
SPARKS NV 89436
Nevada contractor's license number issued by the State Contractor's Board 76130
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2289
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 9-5-11

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)

40.436535 °N NAD27
117.915313 °W D.D.

(NSPO 3-08) (O) 627