STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115609
Permit No.
Basin 070

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68258

1. OWNER Keith Kubichek
MAILING ADDRESS 4062 W. Winnemucca Blvd, Winnemucca NV, 89445

ADDRESS AT WELL LOCATION 4064 W. Winnemucca Blvd
Winnemucca, NV
Subdivision Name: County: Humboldt

2. LOCATION SW¼NW¼ Sec1T35N/ R37E
PERMIT/WAIVER NO. N/A (Issued by Water Resources) 013-022-05 (Parcel. No.)

Latitude 40°56.459 Longitude 117°46.301
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Gravel		140	150	10
Clay		150	170	20
Sand & Gravel		170	190	20
Clay		190	210	20
Sand & Fine gravel	X	210	235	25

Dupono Well Log # 43934

RECEIVED 2012 AUG 30 AM 10:31 STATE ENGINEERS OFFICE

Date started: July 16, 20 12
Date completed: July 17, 20 12

7. Water Level
Static water level: 15 feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: Cool °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40-50		2
	40.941080°N	NAD 27
	117.770720°W	

9. WELL CONSTRUCTION
Depth Drilled 140/235 Feet Depth Cased 235 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	140 Feet	235 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	8	.188	135	235

Perforations:
Type of perforation Factory Cut Slots
Size of perforation 3/32 X 4
From 195 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement Exist to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson Drilling, Inc. (CONTRACTOR)
Address 10760 S. Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date July 26, 2012

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com