STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115625
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK + Dena

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69412

1. OWNER Jeff Wheeler
MAILING ADDRESS 150 Blossom Springs Dr
Battle Mtn NV 89820

ADDRESS AT WELL LOCATION 150 Blossom Springs
Dr. Battle Mtn NV 89820
Subdivision Name: County: Lander

2. LOCATION SE ¼ SE ¼ Sec 24 T 32 N/S R 44 E
PERMIT/WAIVER No. 011-074-04
Issued by Water Resources Parcel No.

Latitude
Longitude

UTM E 503536 ☒ NAD 27
N 4496890 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Reconditioning
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	6	6
Tan Clay		6	20	14
Tan Rocky clay		20	40	20
Blue Rocky clay		40	80	40
Tan Rocky clay		80	100	40
Loose Rocky clay		100	120	20

RECEIVED 2012 AUG -9 AM 11:15 WATER ENGINEERS OFFICE

Date started: 7-26, 20 12
Date completed: 7-27, 20 12

7. Water Level
Static water level: 38 ft. feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary 75+	Unk	1½ Hrs.

9. WELL CONSTRUCTION
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	120 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	120

Perforations:
Type of perforation Sawed (PVC Pipe)
Size of perforation 5/16 x 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 5 to 60 ☐ Pumped ☒ Poured
☐ [redacted] to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 90 to 120 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☒ Yes ☐ No 60 to 90 ☐ Pumped ☒ Poured
Type: 3/8

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number
Issued by the *State Contractor's Board* 0009605A
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1807
Signed (By driller performing actual drilling on site or contractor) Joe Boggio
Date

(Rev. 06-06) USE ADDITIONAL SHEETS IF NECESSARY

40.624734 °N
116.958193 °W NAD27