— CORRECTED —

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115650
Permit No.
Basin 064

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69411

1. OWNER Kimberlie Davis (Paul Buffington, T 44)
MAILING ADDRESS P.O. Box 463
BATTLE MTN NV 89820-0463

ADDRESS AT WELL LOCATION 2425 ALLEN Rd.
BATTLE MTN NV 89820
Subdivision Name:
County: LANDER

2. LOCATION SE ¼ SE ¼ Sec 2 T 32 N S R 45 E
PERMIT/WAIVER No. SW (Issued by Water Resources)
010-260-06 Parcel No.

Latitude 40.67024 N
Longitude 116.99609 W
UTM E 506477 N 4501926 ☒ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	8	8
ROCKY CLAY		8	20	12
SANDY CLAY		20	50	30
BLUE CLAY + GRAVEL		50	80	30
TAN CLAY		80	90	10
BLUE CLAY		90	120	30
TAN SANDY CLAY		120	160	40
TAN SAND + GRAVEL		160	200	40

Corrections per Bob Coache -CC

RECEIVED 2012 AUG -9 AM 11:15 STATE ENGINEERS OFFICE

Date started: 7-16, 20 12
Date completed: 7-26, 20 12

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 inches	0 Feet	200 Feet
inches	Feet	Feet
inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	200

Perforations:
Type of perforation Torch Cut
Size of perforation 3/16 X 3"
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 5 to 60 ☐ Pumped ☒ Poured
☐ to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 120 to 200 ☐ Pumped ☒ Poured
Type: 3/8
Bentonite Chips: ☒ Yes ☐ No 60 to 120 ☐ Pumped ☒ Poured
Type: 3/8

7. Water Level
Static water level: 45 ft feet below land surface
Artesian Flow: / G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Good

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Rotary	75+	Unk	3 Hrs.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LBJ DRILLING & PUMP COMPANY, INC. (Contractor)
Address P.O. BOX 902 - Winnemucca, NV 89446 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0009605A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1807
Signed (By driller performing actual drilling on site or contractor) Joe Boggio
Date

(Rev. 06-06) USE ADDITIONAL SHEETS IF NECESSARY

40.670176 °N
116.924150 °W NAD27