

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48962

1. OWNER Harold + Carmen Farias ADDRESS AT WELL LOCATION # 9 W.C.O.  
 MAILING ADDRESS # 9 Wellington Wellington Nev. 89444  
Cutt off Wellington Rd. 89444 9 Wellington Cut-off  
 2. LOCATION N.W. NW 1/4 Sec. 12 T. 10 S. R. 23 E. Lyon County  
 PERMIT NO. 0-10-661-07 Parcel No. 010-661-07 Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>sandy clay</u>				
<u>small rock</u>				
<u>top soil</u>		<u>0</u>	<u>26</u>	<u>26</u>
<u>brwn clay</u>				
<u>with some</u>				
<u>small rock</u>		<u>26</u>	<u>40</u>	<u>14</u>
<u>sharp gravel</u>	<u>yes</u>			
<u>with brwn</u>				
<u>clay mix</u>		<u>40</u>	<u>68</u>	<u>28</u>
<u>hard brwn</u>				
<u>clay with</u>				
<u>some small</u>		<u>68</u>	<u>85</u>	<u>17</u>
<u>rock</u>				
<u>per gravel</u>				
<u>to case</u>				
<u>cord</u>	<u>yes</u>	<u>85</u>	<u>106</u>	<u>21</u>

8. WELL CONSTRUCTION  
 Depth Drilled 106 Feet Depth Cased 106 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 Inches 0 Feet 50 Feet  
6 Inches 50 Feet 106 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>1 9/8</u>	<u>0</u>	<u>106</u>

 Perforations:  
 Type perforation Factory saw slott  
 Size perforation 86/114 x 13  
 From 86 feet to 106 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started Oct 16, 2004  
 Date completed Oct 18, 2004

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>10 ft</u>	<u>3 hrs</u>

9. WATER LEVEL  
 Static water level 35 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 115 °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Mills Drilling Contractor  
 Address P.O. Box 92 Contractor  
Smith Pk. 89430  
 Nevada contractor's license number 32166A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 718  
 Division of Water Resources, the on-site driller  
 Signed Edmund Mills  
 By driller performing actual drilling on site or contractor  
 Date Oct 18 - 04