STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115784
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36816

1. OWNER Town Center 3 LLC
MAILING ADDRESS 901 N. Green Valley Pkwy #200 Henderson NV. 89074-7105
ADDRESS AT WELL LOCATION 4300 E. Sunset Road Henderson, NV 89074
Subdivision Name: County: Clark

2. LOCATION SW ¼ SW ¼ Sec. 32 T 21 N/S R 62 E
PERMIT/WAIVER No. 161-32-412-009
Issued by Water Resources Parcel No.
Latitude N36° 04' 21.0" Longitude W115° 04' 48.2"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84
Client # MW-16

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL A/C over Aggl base		0	1	1
FILL CLAYEY SAND		1	4	3
SANDY GRAVEL w/ SD. GYP		4	9	5
CALICHE		9	10	1
SANDY GRAVEL w/ cobbles		10	16	6
CALICHE		16	17	1
SANDY GRAVEL	wet	17	18	1
CALICHE		18	27	9
SANDY CLAY		27	29	2
CALICHE		29	31	2
SILTY CLAY		31	31½	½
CALICHE		31½	33	1½
SILTY CLAY		33	33½	½
CALICHE		33½	34	½
SILTY CLAY		34	35½	1½
CALICHE		35½	36	½
SILTY CLAY		36	36½	½
CALICHE		36½	38½	2
SILTY CLAY		38½	40	1½

Date started: 9/21, 2012
Date completed: 9/21, 2012

7. Water Level
Static water level: 19.6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Drawdown (Feet Below Static)	Time (Hours)
NA		

DCNR/DWR RECEIVED OCT 19 2012 LAS VEGAS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6	Inches	0	Feet	40	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch	40 PVC	ASTM F-480	0	40

Perforations:
Type of perforation Factory Slots
Size of perforation 020

From 20	feet to	40	feet
From	feet to		feet
From	feet to		feet
From	feet to		feet
From	feet to		feet

Annular Seal: ☒ Yes ☐ No

☐ Neat Cement	to		☐ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☒ Concrete Grout	0	to 5	☐ Pumped	☒ Poured
☐ ≥30% Bentonite Grout		to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 18 to 40 ☐ Pumped ☐ Poured
Type: #8 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No 5 to 18 ☐ Pumped ☒ Poured
Type: Hydrated ¾ Bentonite Hole Plug

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 4255 W. Post Rd. (Contractor)
Las Vegas NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 05931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas M. Beall (By driller performing actual drilling on-site or contractor)
Date 10/17/12

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 05-06)
(NSPO 3-08)
(O) 627

36.0725259
115.0792263 - NAD 27