STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115820
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33752

1. OWNER Christopher Guild
MAILING ADDRESS PO Box 905
Caliente, NV 89008

ADDRESS AT WELL LOCATION 3263 Mabel Trail
Subdivision Name:
County: Lincoln County

2. LOCATION NW ¼ SE ¼ Sec 3 T 3 N/S R 67 E
PERMIT/WAIVER No. 013-190-09
Issued by Water Resources Parcel No.

Latitude N 37.71501
Longitude W 114.46907

UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
40% Coarse Sand, 40% Gravel, 20% Clay		0	80	80
90% Clay, 10% Med. Sand		80	290	210
Gravel		290	295	5
Clay		295	300	5

DCNR/DWR
RECEIVED
OCT 09 2012
LAS VEGAS OFFICE

Date started: Sept. 27, 20 12
Date completed: Oct. 1, 20 12

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8"	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02		+2	20
6.625	5.006	.390 (SDR17)	20	300

Perforations:
Type of perforation Mill
Size of perforation 1/8 x 2 1/2 x 6
From 240 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 300 ☐ Pumped ☒ Poured
Type: 3/8"
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 150 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		1 1/2 HRS.

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2471
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 10-4-12

(Rev. 05-06)
USE ADDITIONAL SHEETS IF NECESSARY

37.715045
114.4682448 - NAD27

(NSPO 3-08) (O) 627