STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115868
Permit No.
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33054

1. OWNER Round Mountain Gold Co
MAILING ADDRESS PO Box 480
Round Mountain NV 89045

ADDRESS AT WELL LOCATION Round Mountain Minesite
Near Round Mountain NV
Subdivision Name: N/A County: NYE

2. LOCATION NW ¼ SW ¼ Sec 19 T 10 (N)S R 44 E
PERMIT/WAIVER No. M/C 1813
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 492359.4 ☒ NAD 27
N 4284232.0 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Volcanics | | 0 | 127 | 127 |
| Meta Sedimentary | | 127 | 924 | 797 |
| Transducers Set @ | | | | |
| 1: 127 | | | | |
| 2: 630 | | | | |
| D-549 | | | | |

Date started: 3-27, 20 12
Date completed: 4-4, 20 12

9. WELL CONSTRUCTION
Depth Drilled 925 Feet Depth Cased 925 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 3.380 HQ | Inches | 0 Feet | 925 Feet |
| | Inches | Feet | Feet |
| | Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 0.500 | 0.114 | 0.472 | 0 | 925 |

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 10 ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☒ ≥30% Bentonite Grout 10 to 925 ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

RECEIVED
2012 APR 13 AM 11:03
STATE ENGINEERS OFFICE

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name National EWP
Contractor
Address 580 West Silver Street
Contractor
Elko NV 89801
Nevada contractor's license number issued by the State Contractor's Board 0075355
Nevada driller's license number issued by the Division of Water Resources the on-site driller 2440
Signed
By driller performing actual drilling on-site or contractor
Date 4-6-2012

(Rev. 05-06) 38.708557 117.087875 NAD27

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)