

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S REPORT

OFFICE USE ONLY

Log No. 115881  
Permit No. \_\_\_\_\_  
Basin 207

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67929

1. OWNER Brice (+Peggy) Gubler  
MAILING ADDRESS PO. Box 206  
LOAD NV 89317  
2. LOCATION NW 1/4 NE 21 T12N R62E  
PERMIT/WAIVER No. 011-530-14

ADDRESS AT WELL LOCATION Lot 4 B Sawmill Estates  
Subdivision Name: Sawmill Estates County: White Pine  
Latitude N 38° 53' 21" UTM E  NAD 27  
Longitude W 115° 00' 33" N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	5	5
sand - boulders		5	55	50
clay		55	100	45
sandy clay	X	100	110	10
hard clay		110	150	40
dry gravel sand	X	150	195	45

9. WELL CONSTRUCTION  
Depth Drilled 195 Feet Depth Cased 195 Feet  
HOLE DIAMETER (BIT SIZE)  
From 0 To 195  
Inches 0 Feet 195  
Inches \_\_\_\_\_ Feet \_\_\_\_\_  
Inches \_\_\_\_\_ Feet \_\_\_\_\_

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>195</u>

Perforations:  
Type of perforation saw cut  
Size of perforation 1/8" x 3/4"  
From 65 feet to 85 feet  
From 105 feet to 125 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout 0 to 50  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 50 to 195  Pumped  Poured  
Type: 1/4" minus  
Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
Type: \_\_\_\_\_

Date started: 9-6-2012 , 20  
Date completed: 9-12-2012 , 20

7. Water Level  
Static water level: 114 feet below land surface  
Artesian Flow: 0 G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold °F  
Quality: good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>	<u>3</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Davis Drilling and Pumps Contractor  
Address HK 61 Box 54 Hiko NV 89012 Contractor  
Nevada contractor's license number 0028266  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 1191  
Division of Water Resources, the on-site driller  
Signed Mark Davis  
By driller performing actual drilling on-site or contractor  
Date 9-12-2012

(Rev. 06-05) 38.886973°N  
115.004667°W NAD27

USE ADDITIONAL SHEETS IF NECESSARY  
(NSPO 3-08) (0) 527