STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115900
Permit No. 64011/69226
Basin 084

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68406

1. OWNER Frank Kujac (3 Minnie)
MAILING ADDRESS PO Box 10104, Reno, NV 89510
ADDRESS AT WELL LOCATION 4555 Bacon Rind
Reno, NV

2. LOCATION SW ¼ SE ¼ Sec 19 T 22N N/S R 21 E
PERMIT/WAIVER No. 64011/69226 (Issued by Water Resources) 076-220-33 (Parcel No.)
Latitude 39.754701
Longitude 119.665742
UTM E / N
☐ NAD 27 ☑ NAD 83/WGS 84
Subdivision Name:
County Washoe

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☑ Deepen ☐ Other...

4. PROPOSED USE
~~☑ Domestic~~
☒ Irrigation + Dom ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other... x mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel	x	450	472	22
Clay		472	492	20
Granite	x	492	565	73
Broken granite	x	565	615	50
Granite	x	615	632	17
Broken granite	x	632	665	33
Garnite	x	665	695	30
Soft granite	x	695	730	35
Granite	x	730	750	20

Deepens well log #65919

RECEIVED 2012 AUG 16 AM 10: 01 STATE ENGINEERS OFFICE

Date started 7/11/2012, 20 12
Date completed 7/20/2012, 20 12

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	225	1
20	325	6
39.754792°N		NAD27
119.664722°W		

8. WELL CONSTRUCTION
Depth Drilled 750 Feet Depth Cased 750 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	450	Feet	750	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5 9/16	6.96	188	435	750

Perforations:
Type of perforation mill slot
Size of perforation 3/32

From	450	feet to	470	feet
From	530	feet to	550	feet
From	590	feet to	610	feet
From	650	feet to	670	feet
From	690 730	feet to	710 750	feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 425 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling, Inc. (Contractor)
Address 4850 Joule St. A5 Reno, NV 89502 (Contractor)
Nevada contractor's license number issued by the *State Contractor's Board* 14170
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 2121
Signed (By driller performing actual drilling on site or contractor)
Date 8/13/2012

(Rev. 06/10)
USE ADDITIONAL SHEETS IF NECESSARY