STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115912
Permit No.
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67818

1. OWNER THOMAS KURACINA
MAILING ADDRESS 3547 MONT BLANC Ct
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 3547 MONT BLANC
MINDEN, NV 89423
Subdivision Name: County: Douglas

2. LOCATION SE ¼ NW ¼ Sec 11 T 14N N/S R 19 E
PERMIT/WAIVER No. 1419-11-001-009
Issued by Water Resources Parcel No.

Latitude 39.09468°N
Longitude 119.81880°W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OLD 8 5/8 WELL		0	80	80
OLD 6 5/8 WELL		80	130	50
COURSE DG SANDS		130	180	50
GRAY DG SANDS	X	180	215	35
FRACTURED DG SANDS	XXX	215	260	45

Date started: 10-Dec, 20 12
Date completed: 13-Dec, 20 12

9. WELL CONSTRUCTION
Depth Drilled 260 ~~130~~ Feet Depth Cased 260 ~~130~~ Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
6 1/8	Inches	130	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	3.78	.216	120	260
SDR 21				

Perforations:
Type of perforation FACTORY MILL SLOT
Size of perforation .032
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement N/A to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No N/A to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 87' feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.
Contractor
Address 20 KIT KAT DRIVE
Contractor
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael Hack
By driller performing actual drilling on site or contractor
Date 12/14/2012

RECEIVED 2012 DEC 18 AM 11 34 STATE ENGINEERS OFFICE

(Rev. 05-08) 39.094771°N 119.817786°W NAD 27

USE ADDITIONAL SHEETS IF NECESSARY