

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 115955
Permit No. _____
Basin No. 108

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69280
WELL NAME (if applicable): _____

1. OWNER/CLIENT NAME Yerington Paiute Tribe
MAILING ADDRESS 603 W Bridge St
Yerington, NV 89447

DETAILED ADDRESS AT WELL LOCATION 180 Wye St
Yerington, NV 89447
Subdivision Name: _____ County: Lyon

2. PLS LOCATION NE 1/4 NW 1/4 20 Sec 14N N/S 25 E
PERMIT/WAIVER NO. _____
Issued by Water Resources Current Parcel No.

Latitude 39.06887 N UTM E NAD 27
Longitude 119.21199 W UTM N NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Deepen: Orig WL# _____
 Replacement: Original well log # NOI # 47757
 Recondition: Original well log # _____

4. PROPOSED USE
 Domestic Irrigation Monitor
 Mining / Dewater Com / Ind Stock
 Test / Other Mun / QM Rec

5. WELL TYPE
 Auger Rotary RVC
 Air Mud Sonic
 Other

6. LITHOLOGIC LOG

| Material Encountered | Lost Circ. | Water Strata | From | To | Thick-ness |
|--|------------|--------------|------|----|------------|
| Brown Sand | | | 0 | 15 | 15 |
| Brown Clay | | | 15 | 18 | 3 |
| Brown Sand | | | 18 | 36 | 18 |
| Gravel | | XX | 36 | 75 | 39 |
| <i>See corresponding plugging NOI # 69279</i> | | | | | |
| 2010 OCT 30 AM 10:10 STATE ENGINEERS OFFICE | | | | | |

9. WELL CONSTRUCTION

Depth Drilled: 75 Feet Depth Cased: 75 Feet

HOLE DIAMETER (BIT SIZE)

| From | To |
|--------------------|------------------------------|
| <u>10</u> Inches | <u>0</u> Feet <u>5</u> Feet |
| <u>6.50</u> Inches | <u>5</u> Feet <u>75</u> Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| <u>2.375</u> | <u>0.96</u> | <u>.218</u> | <u>0</u> | <u>75</u> |
| <u>6.625</u> | <u>12.92</u> | <u>.188</u> | <u>0</u> | <u>5</u> |

PERFORATIONS:

Type of perforation: Well Screen
Size of perforation: 0.01

From 60 Feet To 65 Feet
From _____ Feet To _____ Feet
From _____ Feet To _____ Feet

ANNULAR MATERIALS

Sanitary Seal 59 to 0
 Neat Cement 20 to 0
 Cement Grout _____ to _____
 Concrete Grout _____ to _____
 Bentonite Chips 59 to 20
 Bentonite Grout _____ to _____
 15 % 20 % Other, explain: _____

Gravel Pack [> 0.2 in.] _____ to _____ Pumped Poured
 Sand Pack [< 0.2 in.] 75 to 59 Pumped Poured
 Other, explain: _____ Pumped Poured

Date started: 5-Oct , 20 12
Date completed: 5-Oct , 20 12

7. WATER QUALITIES
Static water level: 34 Feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Unknown

8. WELL TEST DATA

Test Method: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Recorded Time (Hours) |
|------------|-------------------------------|-----------------------|
| <u>39</u> | <u>068952</u> | <u>N NAD027</u> |
| <u>119</u> | <u>211002</u> | <u>W</u> |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, Inc Contractor
Address P.O. Box 1265 Fallon, NV 89407 Contractor

Nevada contractor's license number as issued by the State Contractor's Board: 29064
Nevada well driller's license number as issued by the Nevada Division of Water Resources (on-site driller): 1753
Signed: [Signature]
By driller performing well drilling on site or contractor
Date: 10/8/2012