STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116008
Permit No.
Basin 177

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69072

1. OWNER Warm Creek Ranch - Mrs. Pitkens
MAILING ADDRESS Warm Creek Ranch, Wells, NV 89835

ADDRESS AT WELL LOCATION Warm Creek Ranch, off U.S. Hwy 93
Subdivision Name: County: Elko

2. LOCATION SE ¼ SE ¼ Sec 13 T 33 N/S R 61 E
PERMIT/WAIVER No. Issued by Water Resources Parcel No.

Latitude 40° 44.274 Longitude 115° 01.654
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt, Gravel (40%)		0	80	80
20% Gravel, Silt		80	200	20
Silt, Sand (20%), Gravel		200	260	60

Date started: Nov. 1, 20 12
Date completed: Nov. 21, 20 12

RECEIVED 2012 DEC 21 AM 11:46 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	.250	+2	40
6.625	5.006	.390 SDR17	40	260

Perforations:
Type of perforation Mill
Size of perforation 1/8 x 2 1/2 x 6
From 200 feet to 220 feet
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 260 ☐ Pumped ☒ Poured
Type: Pea
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 29 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 HR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2459
Signed Trevor Gardner (By driller performing actual drilling on-site or contractor)
Date 12-19-12

(Rev. 03-08) 40.737974°N 115.026690°W NAD27 USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627