STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116010
Permit No.
Basin 137B

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69230

1. OWNER Round Mountain Gold Corp. well ID: RP2-2
MAILING ADDRESS P.O. Box 480
Round Mountain, NV. 89045

ADDRESS AT WELL LOCATION South Rib II
Subdivision Name: County: Nye

2. LOCATION SW¼SW¼ Sec1T9N/ R43E
PERMIT/WAIVER NO. NEV2012102 (Issued by Water Resources) Parcel. No.

Latitude
Longitude
UTM E 490770 ☒ NAD 27
N 4279137 ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	300	300
Neat Cement		0	20	20
3/8" Hole Plug		20	97	77
#8 Silica Sand		97	300	203

Date started: November 8, 20 2012
Date completed: November 8, 20 2012

RECEIVED 2012 DEC 14 AM 11:16 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 299 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9.875 Inches	0 Feet	20 Feet
6.5 Inches	20 Feet	300 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	17.02	.250	+3	5
2.375	95.08	.218	+1	299

Perforations:
Type of perforation Slotted
Size of perforation .020
From 99 feet to 299 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 97 to 300 ☒ Pumped ☐ Poured
Type: #8 Silica Sand
Bentonite Chips: ☒ Yes ☐ No 20 to 97 ☒ Pumped ☐ Poured
Type: 3/8" Hole Plug

7. Water Level
Static water level: N/A feet below land surface
Artesian Flow: N/A G.P.M. N/A P.S.I
Water Temperature: N/A °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A	N/A	N/A
38.	662626 °N	NAD 27
117.	106 087 °W	

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boart Longyear (CONTRACTOR)
Address 2745 California Ave. (CONTRACTOR)
SLC., UT. 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2258
Signed
By driller performing actual drilling on site or contractor
Date December 10, 2012

Forms Provided by Forms-On-A-Disk · (214) 340-9429 · FormsOnADisk.com