**STATE OF NEVADA**

**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116011
Permit No.
Basin 137B

**PRINT OR TYPE ONLY**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **69235**

1. OWNER **Round Mountain Gold Corp.** well ID? **RP2-8**
MAILING ADDRESS **P.O. Box 480**
**Round Mountain, NV. 89045**

ADDRESS AT WELL LOCATION **South Rib II**
*Subdivision Name:* *County:* **Nye**

2. LOCATION **SE¼NE¼** Sec**11**T**9**N/ R**43**E
PERMIT/WAIVER NO. **NEV2012102** *Issued by Water Resources* Parcel. No.

Latitude
Longitude
UTM E **490078** ☒ NAD 27
N **4278451** ☐ NAD 83/WGS 84

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. **LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| **Alluvium** | | 0 | 100 | 100 |
| **Neat Cement** | | 0 | 20 | 20 |
| **3/8" Hole Plug** | | 20 | 57 | 37 |
| **#8 Silica Sand** | | 57 | 100 | 43 |

Date started: **November 8**, 20 **12**
Date completed: **November 8**, 20 **12**

RECEIVED 2012 DEC 14 AM 11:15 STATE ENGINEERS OFFICE

9. ***WELL CONSTRUCTION***
Depth Drilled **100** Feet Depth Cased **99** Feet

***HOLE DIAMETER (BIT SIZE)***

| | From | To |
|---|---|---|
| **9.875** Inches | **0** Feet | **20** Feet |
| **6.5** Inches | **20** Feet | **100** Feet |
| Inches | Feet | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| **6.625** | **17.02** | **.250** | **+3** | **5** |
| **2.375** | **95.08** | **.218** | **+1** | **99** |

***Perforations:***
Type of perforation **Slotted**
Size of perforation **.020**
From **59** feet to **99** feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

*Annular Seal:* ☒ Yes ☐ No
☒ Neat Cement 0 to 20 ☒ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 57 to 100 ☒ Pumped ☐ Poured
Type: **#8 Silica Sand**
Bentonite Chips: ☒ Yes ☐ No 20 to 57 ☒ Pumped ☐ Poured
Type: **3/8" Hole Plug**

7. *Water Level*
*Static water level:* **N/A** feet below land surface
Artesian Flow: **N/A** G.P.M. **N/A** P.S.I
Water Temperature: **N/A** °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| **N/A** | **N/A** | **N/A** |
| | | |
| | | |
| 38. | 656427°N NAD27 | |
| 117. | 113997°W | |
| | | |
| | | |

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name **Boart Longyear** (CONTRACTOR)
Address **2745 California Ave.** (CONTRACTOR)
**SLC., UT. 84104**
Nevada contractor's license number issued by the *State Contractor's Board* **0021976**
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* **2258**
Signed
By driller performing actual drilling on site or contractor
Date **December 10, 2012**