STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116081
Permit No
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36818

1. OWNER County of Clark (Pk & Comm Serv)
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas, NV. 89155-0000

ADDRESS AT WELL LOCATION None
Subdivision Name
County Clark

2. LOCATION NW 1/4 SE 1/4 Sec 26 T 21 N/S 0 62 E
PERMIT/WAIVER No. MO2939 (issued by Water Resources) 161-26-701-001 (Permit No)

Latitude N.36.091518°
Longitude W115.018627
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel w/sp. cob		0	1/2	1/2
Sandy Clay w/silt		1/2	1 1/2	1
Clayey Silt w/sand		1 1/2	3	1 1/2
Sandy Clay w/gr.		3	6	3
Sand w/gr, Tr. silt	wet	6	15	9

DCNR/DWR
RECEIVED
NOV 21 2012
LAS VEGAS OFFICE

Date started: 11/15, 20 12
Date completed: 11/15, 20 12

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

9. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 13'8" Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
8	Inches	0	Feet	15	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch 40 PVC ASTM F480			0	13'8"

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 3'8" feet to 13'8" feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 1'8" ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☒ Yes ☐ No 3'2" to 13'8" ☐ Pumped ☒ Poured
Type: #8 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No 1'8" to 3'2" ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug Hydrated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc (Contractor)
Address 4255 W Post Rd (Contractor)
Las Vegas NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas N. Beall (By driller performing actual drilling on-site or contractor)
Date 11/20/12

USE ADDITIONAL SHEETS IF NECESSARY

36.091543
-115.017798 NAD 27

(NSPO 3-08) (0) 627