

**STATE OF NEVADA**  
**DIVISION OF WATER RESOURCES**  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 116.096  
 Permit No. \_\_\_\_\_  
 Basin 071

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **69594**

1. OWNER Ignacio Herrera & Lynanne  
 MAILING ADDRESS 8175 Stinson Winnemucca, NV

ADDRESS AT WELL LOCATION **8175 Stinson Winnemucca, NV 89445**

2. LOCATION NW 1/4 NW 1/4 Sec 24 T35 N R37E  
 PERMIT/WAIVER NO. N/A 014-111-18  
Issued by Water Resources Parcel No.

Subdivision Name: \_\_\_\_\_ County: **Humboldt**  
 Latitude 40°53.873 UTM E  NAD 27  
 Longitude 117°46.511 N  NAD 83/WGS 84

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Gravel		120	125	5
Clay		125	130	5
Sand/Gravel	X	130	170	40
Clay		170	190	20
Sand/Gravel	X	190	215	25
<i>Original Well Log Unknown</i>				

9. WELL CONSTRUCTION  
 Depth Drilled 215 Feet Depth Cased 215 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From \_\_\_\_\_ To \_\_\_\_\_  
6 1/4 Inches 120 Feet 215 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5</u>	<u>8</u>	<u>.188</u>	<u>115</u>	<u>215</u>

Perforations:  
 Type of perforation **Factory Cut**  
 Size of perforation **3/32 X 4**  
 From 175 feet to 215 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Annular Seal:  Yes  No  
 Neat Cement Exist to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Gravel Pack:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_  
 Bentonite Chips:  Yes  No \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

Date started: **December 18, 2012**  
 Date completed: **December 19, 2012**

7. Water Level  
 Static water level: 116 feet below land surface  
 Artesian Flow: N/A G.P.M. N/A P.S.I.  
 Water Temperature: Cool °F  
 Quality: **Good**

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>		<u>4</u>
		<u>7140 27</u>	
		<u>40.897 980°N</u>	
		<u>117.774 220°W</u>	

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **Fred Anderson Drilling, Inc.**  
(CONTRACTOR)  
 Address **10760 S. Grass Valley Road**  
(CONTRACTOR)  
**Winnemucca, NV 89445**  
 Nevada contractor's license number issued by the State Contractor's Board **021467**  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller **2083**  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date **January 10, 2013**