STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116098
Permit No.
Basin 044

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67593

1. OWNER VICTORIA GOLD CORP.
MAILING ADDRESS 1015 TELEGRAPH ST. SUITE B
RENO, NV 89502

ADDRESS AT WELL LOCATION
BSMW-8B
Subdivision Name: RURAL LANDS County: ELKO

2. LOCATION SE ¼ NE ¼ Sec 2 T 43N N/S R 53 E
PERMIT/WAIVER No. M/O-1718 NFS LAND
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0586015 [X] NAD 27
N 4601901 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BACK FILL		0	2	2
CLAY		2	26	24
HARD ROCK		26	417 1/2	392
1ST WATER @ 210'				
2ND WATER @ 350'				
3RD WATER @ 360'				
CASING INSTALLED WITH				
PLASTIC CAP ON TOP &				
BOTTOM				
358' TO 360 1/2' BENTONITE				
PELLETS PLACED				
6" X 8' STEEL CASING				
MONUMENT w/LOCKING CAP				
INSTALLED IN A 3' X 3' X 6"				
CONCRETE PAD				
30' TO 358' 30% BENTONITE				
GROUT PUMPED				

Date started: 17-Oct , 20 11
Date completed: 27-Oct , 20 11

9. WELL CONSTRUCTION
Depth Drilled 417 1/2 Feet Depth Cased 417 1/2 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
7 7/8	Inches	0	Feet	205	Feet
6 1/2	Inches	205	Feet	417 1/2	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 80, PVC	+2	417 1/2
6.625	13	.188	+2 1/2	5 1/5

Perforations:
Type of perforation FACTORY PERFORATED PLASTIC
Size of perforation 0.020 SLOT
From 362 1/2 feet to 412 1/2 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 0 to 20 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[X] ≥30% Bentonite Grout 30 to 358 [X] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 360 1/2 to 417 1/2 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 20 to 30 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 286 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 64 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125 PSI @	60		2 1/2 HOURS
825 CFM			

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1408-T1
Signed (By driller performing actual drilling on site or contractor)
Date 11/1/2011

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

41.566,077°N NAD27
115.968,406°W Dec/Deg