STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116101
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36819

1. OWNER County of Clark (PK & Comm Serv)
MAILING ADDRESS 500 S. Grand Central Pkwy
Las Vegas, NV 89155-0000

ADDRESS AT WELL LOCATION Non
Subdivision Name: County Clark

2. LOCATION NW SW ¼ Sec 23 T 21 N/S R 62 E
PERMIT/WAIVER No. MO-2941 1161-23-301-003
Issued by Water Resources Parcel No.

Latitude N 36.107556° UTM E ☐ NAD 27
Longitude W 115.029027 N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clayey Silt w/salts		0	1	1
Silty Clay w/salts, sand		1	3	2
Clayey Sand w/ silt		3	6	3
Sand w/ silt	wet	6	7	1
Sandy Clay w/silt		7	11	4
Sand w/ silt	4	11	15	4

DCNR/DWR
RECEIVED
NOV 21 2012
LAS VEGAS OFFICE

Date started: 11/19/ , 20 12
Date completed: 11/19 , 20 12

7. Water Level
Static water level: 6 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

9. WELL CONSTRUCTION
Depth Drilled 15 Feet Depth Cased 15 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	15 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" sch	40 PVC	ASTM F-480	0	15

Perforations:
Type of perforation Factory Slots
Size of perforation .020
From 5 feet to 15 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout 0 to 1½ ☐ Pumped ☒ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 4 to 15 ☐ Pumped ☒ Poured
Type: #8 Monterey Sand
Bentonite Chips: ☒ Yes ☐ No to ☐ Pumped ☒ Poured
Type: 3/8 Bentonite Hole Plug - Hydrated

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Elite Drilling Inc. (Contractor)
Address 4255 W Post Rd. (Contractor)
Las Vegas, NV 89118
Nevada contractor's license number issued by the State Contractor's Board 054931
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1944
Signed Thomas J. Beall
By driller performing actual drilling on-site or contractor
Date 11/19/12

USE ADDITIONAL SHEETS IF NECESSARY

36.107582
115.028198 - NAD 27

(NSPO 3-08) (R) 627