

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 00187

1. OWNER City of Carson City ADDRESS AT WELL LOCATION 4005 Carson St. Legislative Mall area Carson City
 MAILING ADDRESS 3505 Both Way Carson City NV 89701

2. LOCATION NW 1/4 SW 17 T 15 N 20 E 39° 09' 46.92" N 119° 46' 00.56" W County Carson City
 PERMIT NO. 004-071-01 Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thick-ness
Well was in good shape. at drill rd down the casing & knocked plug out pump grouted from bottom to top.	15	0	30	
Plug well log	1116	32		

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	Feet
From _____	To _____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>				

Perforations:

Type perforation _____
 Size perforation _____

From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 30
 Cement Grout
 Placement Method: Pumped Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 1/22, 2013
 Date completed 1/22, 2013

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
	<u>N/A</u>		<u>NAD 27</u>
			<u>39.163124° N</u>
			<u>119.765808° W</u>

9. WATER LEVEL

Static water level 15 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Anakresen Drilling Contractor
 Address 11025 Belford rd. Reno, NV 89509 Contractor

Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028

Signed [Signature] By driller performing actual drilling on site or contractor
 Date 1/30/13

RECEIVED
 2013 FEB -4 AM 11:09
 STATE ENGINEERS OFFICE