STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No 116135
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.240

NOTICE OF INTENT NO. 35759

1. OWNER Kevin + Gardi Skehan
MAILING ADDRESS 6765 Mustang ST LV NV. 89131

ADDRESS OF WELL LOCATION Kyle Canyon + Scottie Rd, Corner NW
Subdivision Name:
County Clark

2. LOCATION SE ¼ NW ¼ Sec 18 T 19 N/S R 59 E/W
Latitude N 36.299425
Longitude W 115.417538
☐ NAD 27
☒ NAD 83/WGS 84
PERMIT/WAIVER No. 126-18-201:002
Issued by Water Resources — Parcel No.

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders		0	190	
Cemented Gravel		190	230	
Solid Rock		230	550	
Fractured Rock + water		550	610	
Solid Rock		610	620	
Fractured Rock + water		620	670	

DCNR/DWR
RECEIVED
JAN 04 2013
LAS VEGAS OFFICE

Date started: 12-11-11, 20
Date completed: 12-22-12, 20

9. WELL CONSTRUCTION
Depth Drilled 670 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
13½	Inches	0	Feet	50	Feet
9⅞	Inches	50	Feet	670	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	22	.188	+2	140
4½	PVC	.480	+1½	670

Perforations:
Type of perforation Factory
Size of perforation .030
From 580 feet to 660 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☒ Concrete Grout to ☒ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 510 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 60.1 °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick
Contractor
Address HC 38 Box 104, LV NV 89166
Contractor
13040 Horse Dr. LV NV 89166
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick
By driller performing actual drilling on-site or contractor
Date 12-22-12

USE ADDITIONAL SHEETS IF NECESSARY

36.299460
-115.416694 - NAD 27

(NSPO 3-06)