STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116143
Permit No.
Basin

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

*Please complete this form it its entirety in accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 36890

1. OWNER Texas Gambling Hall & Hotel Inc % Fertitta
MAILING ADDRESS P.O. Box 379045
Las Vegas, NV 89137-9045

ADDRESS AT WELL LOCATION North Las Vegas
MW-6

2. LOCATION NW ¼ NE ¼ Sec 19 T 20S N/S R 61 E
PERMIT/WAIVER No. 139-19-502-001
Issued by Water Resources Parcel No.

Latitude 36 12'00.24"N UTM E ☐ NAD 27
Longitude 115 11'45.23"W N ☑ NAD 83/WGS 84
Subdivision Name: County: Clark

3. WORKED PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other...

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other... Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill | | 0 | 2 | 2 |
| Sandy Clay | | 2 | 7 | 5 |
| Caliche | | 7 | 9 | 2 |
| Sandy Clay | | 9 | 14 | 5 |
| Silty Clay | | 14 | 20 | 6 |
| Sandy Clay | | 20 | 32 | 12 |

DCNR/DWR
RECEIVED
JAN 11 2013
LAS VEGAS OFFICE

Date started 18-Dec , 20 12
Date completed 18-Dec , 20 12

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|---|
| n/a | | | |

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 32 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 4.5 | | Sch 40 | 0 | 32 |

Perforations:
Type of perforation Factory Slotted
Size of perforation 0.02
From 17 feet to 32 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 13
Placement Method: ☐ Pumped ☑ Poured
Gravel Packed: ☑ Yes ☐ No
From 15 feet to 32 feet

Seal Type:
☑ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 23.5 feet below land surface
Artesian flow G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cascade Drilling L.P.
Contractor
Address 555 S. Harbor Blvd
Contractor
La Habra, CA 90631
Nevada contractor's license number issued by the State Contractor's Board C23 0073966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2432
Signed Michael Thomas
By driller performing actual drilling on site or contractor
Date 12/26/12

(Rev. 06/10)

USE ADDITIONAL SHEETS IF NECESSARY

36.200098
-115.195061 - NAD 27