WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 116147
Permit No. 76749+76750
Basin 107

NOTICE OF INTENT NO. 60353

1. OWNER larry Roberts and Jim Bluff
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOWER COLONY
NW 155.9 wd vrd

2. LOCATION NW ¼ NE ¼ SE ¼ Sec. 22 T. 11 N/S R. 23 E/W 140W County
PERMIT NO. 76749+76750 (Issued by Water Resources) ~~10-301-21~~ 010-301-23 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
~~☒ Domestic~~ ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND		0	16	16
BROWN CLAY - SAND	X	16	48	32
PINK SILTY CLAY	X	48	160	112
BROWN SILTY CLAY	X	160	218	58
MEDIUM GRAVEL - SAND	X	218	300	82

RECEIVED 2013 FEB 11 PM 2:56 STATE ENGINEERS OFFICE

NAD 83?
38.80186° N
119.39116° W

Date started 15 NOV, 2007
Date completed 17 NOV, 2007

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25+		3.5
NAD 27		
38.80194 9°N		
119.3901 65°W		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	300 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	300

Perforations:
Type perforation Factory milled
Size perforation 3/32" x 3"
From feet to feet
From feet to feet
From 120 feet to 300 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 106 ft
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 106 feet to 300 feet

9. WATER LEVEL
Static water level 84 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name BLAIN DRILLING & PUMP CO INC.
Address P.O. Box 1255 Carson City, NV 89702
Contractor

Nevada contractor's license number issued by the State Contractor's Board 46498
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2167
Signed Jack Dotson
By driller performing actual drilling on site or contractor
Date 9 DEC 07

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627