STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116242
Permit No.
Basin 162

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36225

1. OWNER PATRICIA DANNENBERGER
MAILING ADDRESS 1621 N ROYAL AVE
PAHRUMP NV 89060-3646

ADDRESS AT WELL LOCATION 1621 N ROYAL AVE
Subdivision Name: LANDMARK SUBDIVISION County: NYE

2. LOCATION SE ¼ NE ¼ Sec 6 T 20S N/S R 53 E
PERMIT/WAIVER No. 36-025-14 (Issued by Water Resources) Parcel No
Latitude N36°14'35.7" Longitude W116°03'14.5"
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	21	21
CALICHIE		21	36	15
CLAY		36	58	22
CALICHIE		58	74	16
CLAY		74	82	8
CALICHIE	WB	82	105	23
CLAY SOFT & SLUFFING		105	118	13
CALICHIE	WB	118	129	11
CLAY		129	148	19
CALICHIE	WB	148	160	12
CLAY		160	175	15
CALICHIE	WB	175	200	25

DCNR/DWR
RECEIVED
JAN 18 2013
LAS VEGAS OFFICE

Date started: 15-Nov, 20 12
Date completed: 3-Dec, 20 12

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	2.37	.248	0	200

Perforations:
Type of perforation SCREEN
Size of perforation .032
From 120 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 57 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING (Contractor)
Address 1220 MANSE RD (Contractor)
PAHRUMP NV 89048
Nevada contractor's license number issued by the *State Contractor's Board* 47333
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1426
Signed (By driller performing actual drilling on site or contractor)
Date 1-17-13

(Rev. 05/08)

USE ADDITIONAL SHEETS IF NECESSARY

36.243250 – 116.054028 NAD 27