

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116299
Permit No. 81336
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67928

1. OWNER Brooktree Park LLC ADDRESS AT WELL LOCATION #9 Brooktree Lane
MAILING ADDRESS PO Box 1465 Round Mt. Nevada NV 89045 Subdivision Name: Santa Court County: NYE
2. LOCATION SE 1/4 SW 1/4 Sec 4 T 10 N R 43 E Latitude N39° 44.263 UTM E NAD 27
PERMIT/WAIVER No. 81336 012-461-05 Longitude W117° 09.629 N NAD 83/WGS 84
Parcel No. (012-461-05)

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	6	6
Sand - boulders		6	25	19
Sand - Gravel	X	25	30	5
Clay sand - Gravel		30	30	0
Clay sand - boulders		30	145	115
Hard Rock		145	151	6
Gravel - clay	X	151	163	12
Clay		163	165	2

9. WELL CONSTRUCTION

Depth Drilled 165 Feet Depth Cased 165 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
<u>11</u>	<u>0</u>	<u>165</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.575</u>	<u>Steel</u>	<u>.188</u>	<u>0</u>	<u>165</u>

Perforations:

Type of perforation 39W cut

Size of perforation 1 3/4 x 3

From	To
<u>99</u>	<u>121</u>
<u>141</u>	<u>163</u>

Annular Seal: Yes No

Neat Cement 0 to 50 Pumped Poured

Cement Grout to Pumped Poured

Concrete Grout to Pumped Poured

≥30% Bentonite Grout to Pumped Poured

Gravel Pack: Yes No to Pumped Poured

Type: 3/8 minus

Bentonite Chips: Yes No to Pumped Poured

Type:

Date started: 7-18-2012, 20
Date completed: 7-20-2012, 20

7. Water Level

Static water level: 2.7 feet below land surface

Artesian Flow: 0 G.P.M. 0 P.S.I.

Water Temperature: cold °F

Quality: Fair

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30</u>	<u> </u>	<u>2</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name: Davis Drilling and Pumps Contractor

Address: HC 61 Box 54 Hiko NV 89017 Contractor

Nevada contractor's license number issued by the State Contractor's Board: 0028966

Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1191

Signed: Mike Davis
By driller performing actual drilling on-site or contractor

Date: 7-21-2012

(Rev. 05-06)
38.749452°N
117.159397°W NAD27
(NSPO 3-08)

USE ADDITIONAL SHEETS IF NECESSARY