

- 73 UNIT MOTEL WELL
IN CARVERS, NV

omg

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116301
Permit No. 81617
Basin 137B

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67926

1. OWNER Kimik LLC ADDRESS AT WELL LOCATION mile marker #53
MAILING ADDRESS HCGO Box 53702 Hwy 376 Carvers NV
Round Mt Nv NV 89045 Subdivision Name: Shoshone County: NYE
2. LOCATION 0.5 SE 1/4 Sec 29 T 11 N R 43 E Latitude N38°46.775 UTM E NAD 27
PERMIT/WAIVER No. 81617 610-321-21 Longitude 117°10.204 N NAD 83/WGS 84
Issued by Water Resources Parcel No.

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP soil		0	9	9
sand-boulders	X	9	40	31
clay-boulders		40	120	80
gravel-clay-boulders	X	120	148	28
clay		148	151	3

9. WELL CONSTRUCTION
Depth Drilled 151 Feet Depth Cased 151 Feet
HOLE DIAMETER (BIT SIZE)
From 0 To 151
Inches 11 Feet
Inches Feet
Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>Steel</u>	<u>1.88</u>	<u>0</u>	<u>151</u>

RECEIVED
2012 AUG 15 AM 10:21
STATE ENGINEERS OFFICE

Perforations:
Type of perforation factory
Size of perforation 1/8" x 5'
From 91 feet to 111 feet
From 131 feet to 151 feet
From feet to feet
From feet to feet

Annular Seal: Yes No
 Neat Cement 0 to 50 Pumped Poured
 Cement Grout to Pumped Poured
 Concrete Grout to Pumped Poured
 ≥30% Bentonite Grout to Pumped Poured
Gravel Pack: Yes No 50 to 151 Pumped Poured
Type: 1/4" MIAUS
Bentonite Chips: Yes No to Pumped Poured
Type: 0

Date started: 8-6-2012, 20
Date completed: 8-8-2012, 20

7. Water Level
Static water level: 36 feet below land surface
Artesian Flow: 0 G.P.M. P.S.I.
Water Temperature: cold °F
Quality: good

8. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>25</u>		<u>1</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling and Pumps
Address HCGO Box 54 Hiko NV 89012
Nevada contractor's license number 0028966
issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis
By driller performing actual drilling on-site or contractor
Date 8-8-2012