

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 116324
 Permit No. 76630
 Basin 207

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 63622

1. OWNER Garth Sinfield
 MAILING ADDRESS HC 34 Box 34001 Ely Nevada 89301
 ADDRESS AT WELL LOCATION 5R 318 Proser Nev
 2. LOCATION NE 1/4 NE 1/4 Sec 2 T 12 N R 61 E White Pine County
 PERMIT NO. 76630 Issued by Water Resources Parcel No. 811-300-31 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand Boulders		0	50	50
Hard Rock		50	85	35
Boulders clay		85	90	5
Fractured Rock		90	105	15
Clay sand Boulders		105	145	40
Hard Rock		145	150	5
grad. sand-clay		150	178	28

GPS N 38° 56' 25"
 W 115° 04' 50"

8. WELL CONSTRUCTION
 Depth Drilled 178 Feet Depth Cased 178 Feet
 HOLE DIAMETER (BIT SIZE)
 From 26 Inches To 0 Feet 178 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>16</u>		<u>1.250</u>	<u>0</u>	<u>178</u>

Perforations:
 Type perforation sew cut
 Size perforation 1 3/8 x 3"
 From 138 feet to 138 feet
 From 138 feet to 178 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 30 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 30 feet to 178 feet

RECEIVED
 2012 JUN -4 AM 11:20
 STATE ENGINEERS OFFICE

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 4-25-2012
 Date completed 5-25-2012

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>7</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89017 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028266
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 5-30-2012