STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116353
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

"Corner of Joey and Shannon St."

NOTICE OF INTENT NO. 64808

1. OWNER Ron Grvey
MAILING ADDRESS P.O. Box 33 Golconda NV.

ADDRESS AT WELL LOCATION Corner of Shannon & Joey Golconda NV.
Subdivision Name: "Golconda" County: Humboldt

2. LOCATION NE ¼ SW ¼ Sec 11 T 36 N/S R 39 E
PERMIT/WAIVER No. 008-59.130
Issued by Water Resources
Parcel No. 5

Latitude 41°00.540
Longitude 117°33.230
UTM E
N
☐ NAD 27
☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. "008-591-30" PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand	NO	0	10	10
gravel, clay	NO	10	55	45
gravel sand clay	yes	55	160	105

RECEIVED 2011 OCT 12 AM 11:36 STATE ENGINEER

Date started: 10-16, 20 10
Date completed: 10-25, 20 10

7. Water Level
Static water level: 67 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	0	4½

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	160 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.188	Steel	0	20
6 5/8	Sched	40 Plastic	20	160

Perforations:
Type of perforation Slot
Size of perforation .125
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Alternative Drilling
Contractor
Address 197 Wester Hills
Contractor
Spring Creek NV.
Nevada contractor's license number issued by the State Contractor's Board 73955
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Gerald Moritz
By driller performing actual drilling on-site or contractor
Date

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

41.009098 °N
117.552876 °W NAD 27

(NSPO 3-08)

(O) 627