

**ORIGINAL**

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY  
Log No. 116369  
Permit No. 60139  
Basin 054

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67742

1 OWNER TOWN OF CRESCENT VALLEY ADDRESS AT WELL LOCATION 1/4 MILE NORTH AND 2 MILES EAST  
MAILING ADDRESS PO BOX 211017 OF THE TOWN OF CRESCENT VALLEY  
NE CRESCENT VALLEY, NEVADA 89821 Subdivision Name: County: Eureka

2 LOCATION NW 1/4 NE 1/4 Sec 6 T 29N N/S R 48 E Latitude 40° 25' 13.5" N UTM E NAD 27  
PERMIT/WAIVER No. W-420-60139 Longitude 116° N 36' 13.8" W N NAD 83/WGS 84  
Issued by Water Resources Parcel No.

3 TYPE OF WELL Is this well being plugged because a replacement well was drilled? YES  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock If yes, what is replacement well NO? 60387 N/A  
Is there an existing well log? YES  
If yes, what is NDWR well log #? 47039

4 EXISTING WELL CONSTRUCTION  
Depth Drilled 410' Feet Depth Cased 400' Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4"		.250"	+1'	400'

Existing Perforations:

Type of perforation	Size of perforation	From	To
WIRE WRAP SCREEN	.120"	250'	270'
		280'	310'
		320'	390'

7 WELL PLUGGING PROCEDURE  
Was well cleaned out to total depth?  yes  no  
If well was not cleaned out to total depth, please explain why:

Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no  
If casing was left in place, please show where additional perforations were made:

Additional Perforations:

Type of perforator used:	From	feet to	Number of perfs per linear foot
HOLT AIR PERFORATOR	87'	250'	5 Rows
	270'	280'	5 Rows
	310'	320'	5 Rows
	390'	400'	5 Rows

5 WATER LEVEL  
Static water level 200' feet below land surface  
Artesian flow NO G.P.M. 0 P.S.I.  
Water temperature COOL ° F Quality

8 WELL PLUGGING MATERIALS

From	feet to	Material Used	<input checked="" type="checkbox"/> Pumped	<input type="checkbox"/> Poured
0'	20'	NEAT CEMENT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
20'	400'	BENTONITE GROUT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

Neat Cement Fluid Weight 15 LBS lbs/gal  
Bentonite Grout 20% % bentonite  
Date Started 12/18/2011  
Date Completed 12/19/2011

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Hydro Resources-West, Inc. Contractor

Address 4975 W. Winnemucca Blvd. Contractor

Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 56797

Nevada driller's license number issued by the Division of Water Resources, the on-site driller # 1713

Signed Michelle Strother By driller performing actual drilling on site or contractor

Date 1/13/2012

RECEIVED  
2012 JAN 17 PM 2:13  
STATE ENGINEERS OF NEV

(Rev. 05-08) 40.420500° N  
116.602913° W

NAD 83 USE ADDITIONAL SHEETS IF NECESSARY