

**STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
WELL DRILLER'S PLUGGING REPORT**

**OFFICE USE ONLY**  
Log No. 116371  
Permit No. 67725  
Basin 087

**PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 67771

**1 OWNER** Truckee Meadows Water Authority  
MAILING ADDRESS 1355 Capital Blvd.  
Reno, NV. 89503

ADDRESS AT WELL LOCATION 1900 Whitewood Drive  
Sparks, NV. 89432  
Subdivision Name \_\_\_\_\_ County: Washoe

**2 LOCATION** SE ¼ SW ¼ Sec 35 T 20N N/S R 20 E  
PERMIT/WAIVER No. 67725 Parcel No. 030-021-09

Latitude N 39.55440 UTM E \_\_\_\_\_  NAD 27  
Longitude W 119.70705 N \_\_\_\_\_  NAD 83/WGS 84

**3 TYPE OF WELL**  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

Is this well being plugged because a replacement well was drilled? no  
Is there an existing well log? yes  
If yes, what is replacement well NOI? \_\_\_\_\_  
If yes, what is NDWR well log #? 85077

**4 EXISTING WELL CONSTRUCTION**  
Depth Drilled 450 Feet Depth Cased 440 Feet

**7 WELL PLUGGING PROCEDURE**  
Was well cleaned out to total depth?  yes  no

**EXISTING CASING SCHEDULE**

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12		.250	+2	440

If well was not cleaned out to total depth, please explain why: \_\_\_\_\_  
Was the well contaminated?  yes  no  
Was the casing pulled?  yes  no  
Was the casing over drilled?  yes  no

**Existing Perforations:**

Type of perforation	Size of perforation	From	To
wire wrap screen <td>0.6</td> <td>280</td> <td>feet</td>	0.6	280	feet
		420	feet
			feet
			feet
			feet

**Additional Perforations:**

Type of perforator used:	From	To	Number of perfs per linear foot
12" Mills Knife	240	100	6

**5 WATER LEVEL**  
Static water level 5.7 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

**8 WELL PLUGGING MATERIALS**

Material Used	From	To	Material Used
neat cement	440	6	<input checked="" type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured
			<input type="checkbox"/> Pumped <input type="checkbox"/> Poured

**6 Additional Notes or Comments**

We removed 360' of 6" drop pipe with a 75hp pump from well. We conducted a video of the well to check condition of screens. The screens were open and we touched bottom at 436'. We bailed debris from well to a depth of 440'. We then installed 12" Mills knife to 240' and perforated 6 rows per foot back up to 100' where we met resistance from sanitary seal. We installed 430' of 2" tremme pipe. The next day, we pumped in 15 cubic yards of neat cement. The existing pitless unit was then cut off 5' below ground level and covered.

Neat Cement Fluid Weight 14.3 lbs/gal  
Bentonite Grout \_\_\_\_\_ % bentonite  
Date Started 9/6/2011  
Date Completed 9/9/2011

**9 DRILLER'S CERTIFICATION**  
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.  
Name Carson Pump, LLC Contractor  
Address P.O. Box 20159 Contractor  
Carson City, NV. 89721  
Nevada contractor's license number issued by the State Contractor's Board 39920A  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482  
Signed [Signature] By driller performing actual drilling on site or contractor  
Date 9/16/2011

STATE ENGINEER'S OFFICE  
2011 SEP 19 PM 12:17

USE ADDITIONAL SHEETS IF NECESSARY

39.552524° N  
119.704967° W NAD27

RECEIVED