STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116916
Permit No. 71441
Basin 105

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69828

1. OWNER WILLIAM GARRISON + Jenny
MAILING ADDRESS 2269 MEADOW LARK LANE
GENOA, NV 89408

ADDRESS AT WELL LOCATION ~~WILLIAM GARRISON~~
2269 MEADOW LARK LANE Genoa, NV
Subdivision Name: County: Douglas

2. LOCATION SW ¼ NE ¼ Sec 10 T 13N N/S R 19 E
PERMIT/WAIVER No. 71441 (Issued by Water Resources) 1319-10-610-004 Parcel No.

Latitude 39.005808*N
Longitude 119.83400*W
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVER BURDEN		0	3	3
BROWN SANDS		3	8	5
GC SANDS		8	24	16
BROWN GRAY CLAY		24	65	41
DG SANDS		85	110	25
COURSE GRAVELS		110	162	52
FRACTURED GRAVELS	XXX	162	200	38

Date started: 25-Jan, 20 2013
Date completed: 30-Jan, 20 2013

RECEIVED 03 FEB -6 AM 11:51 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	200	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	20
6 5/8	4.26	.216	20	200
SDR 21				

Perforations:
Type of perforation FACTORY SLOT
Size of perforation .032
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 100 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 100 to 200 ☐ Pumped ☒ Poured
Type: PEAT GRAVEL
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 0 feet below land surface
Artesian Flow: YES G.P.M. 5 P.S.I.
Water Temperature: COLD °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	65	3 HRS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC. (Contractor)
Address 20 KIT KAT DRIVE (Contractor)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the *State Contractor's Board* 0055548
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1905
Signed (By driller performing actual drilling on site or contractor)
Date 02/02/2013

(Rev. 05-08) USE ADDITIONAL SHEETS IF NECESSARY

39.005900°N
119.832987°W
NAD27