

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT

OFFICE USE ONLY
Log No. 116456
Permit No. 11382
Basin 139

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68640

1 OWNER Russ Fitzwater ADDRESS AT WELL LOCATION Kobeh Valley-Grimes Ranch
MAILING ADDRESS 13159 W Highway 56 Eureka, NV 89316
Cedar City, UT 84720 Subdivision Name: _____ County: _____

2 LOCATION SW ¼ NE ¼ Sec 7 T 18N N/S R 48 E Latitude 39.44094 N UTM E NAD 27
PERMIT/WAIVER No. 11382 Longitude -116.60854 W N NAD 83/WGS 84
Issued by Water Resources Parcel No. _____

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
Is this well being plugged because a replacement well was drilled? yes
If yes, what is replacement well NO? 68639 Is there an existing well log? no
If yes, what is NDWR well log #? _____

4 EXISTING WELL CONSTRUCTION
Depth Drilled _____ Feet Depth Cased _____ Feet

EXISTING CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	0	220

Existing Perforations:
Type of perforation _____ Unknown
Size of perforation _____
From _____ feet to _____ feet
From _____ feet to _____ feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no
If casing was left in place, please show where additional perforations were made:
Additional Perforations:
Type of perforator used: Air Roller

From	feet to	feet	Number of perfs per linear foot
0	220	feet	4

5 WATER LEVEL
Static water level 125 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

8 WELL PLUGGING MATERIALS

From	feet to	feet	Material Used	<input type="checkbox"/> Pumped	<input type="checkbox"/> Poured
50	220	feet	20% Grout	<input checked="" type="checkbox"/>	<input type="checkbox"/>
0	50	feet	Neat Cement	<input checked="" type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>
				<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments

Pumped 20% bentonite from bottom to 50 feet.
50 feet to surface neat cement.

Neat Cement Fluid Weight 15.9 lbs/gal
Bentonite Grout 20 % bentonite
Date Started 5/29/2012
Date Completed 5/29/2012

9 DRILLER'S CERTIFICATION

This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.
Contractor

Address P.O. Box 1265
Contractor

Fallon, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2307

Signed Wayne Judd
By driller performing or drilling on site or contractor

Date 6/28/2012

RECEIVED
2012 JUL 24 AM 11:24
STATE ENGINEERS OF FLORIDA

USE ADDITIONAL SHEETS IF NECESSARY

39.441012°N
116.607630°W NAD27

(Rev 05-08)