

**STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S PLUGGING REPORT**

OFFICE USE ONLY

Log No. 116482
Permit No. 61401
Basin 103

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

*Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340*

NOTICE OF INTENT NO. 69821 ✓

1 OWNER LYON COUNTY UTILITIES
MAILING ADDRESS 34 LAKES BLVD
DAYTON, NV 89403

ADDRESS AT WELL LOCATION OLD COMO RD NO ADDRESS
DAYTON, NV 89403
Subdivision Name: _____ County: Lyon

2 LOCATION NE ¼ SE ¼ Sec 24 T 16N N/S R 21 E
PERMIT/WAIVER No. 61401 N/A
Issued by Water Resources Parcel No.

Latitude 39.23729°N UTM E NAD 27
Longitude 119.57010°W N NAD 83/WGS 84

3 TYPE OF WELL
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

Is this well being plugged because a replacement well was drilled? NO
Is there an existing well log? YES
If yes, what is replacement well NOI? _____
If yes, what is NDWR well log #? 63881

4 EXISTING WELL CONSTRUCTION
Depth Drilled 202 Feet Depth Cased 200 Feet

7 WELL PLUGGING PROCEDURE
Was well cleaned out to total depth? yes no
If well was not cleaned out to total depth, please explain why: _____

EXISTING CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42.05	.250	2	200

Was the well contaminated? yes no
Was the casing pulled? yes no
Was the casing over drilled? yes no

Existing Perforations:

Type of perforation	Size of perforation	From	To
WIRE WRAP	100 SLOT		

Additional Perforations:

Type of perforator used:	From	To	Number of perfs per linear foot
N/A			

5 WATER LEVEL
Static water level N/A feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality POOR

8 WELL PLUGGING MATERIALS

From	To	Material Used	Pumped	Poured
0	40	NEAT	<input checked="" type="checkbox"/>	<input type="checkbox"/>
40	200	BENTONITE CHIPS	<input type="checkbox"/>	<input checked="" type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>
			<input type="checkbox"/>	<input type="checkbox"/>

6 Additional Notes or Comments
PLACED BENTONITE CHIPS FROM BOTTOM OF WELL TO 40' FROM SURFACE THEN PLACED A NEAT CEMENT PLUG TO SURFACE AND THEN PLACED CEMENT GROUT TO TOP OFF WELL AS IT FELL BACK

Neat Cement Fluid Weight 94/4 lbs/gal
Bentonite Grout _____ % bentonite
Date Started 11/20/2012
Date Completed 11/20/2012

9 DRILLER'S CERTIFICATION
This well was plugged and abandoned under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC
Address 20 KIT KAT DRIVE
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed [Signature]
Date 11/24/2012

(Rev. 05-06) 39.237377°N
119.569013°W NAD27

USE ADDITIONAL SHEETS IF NECESSARY