STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116508
Permit No.
Basin 048

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67997

1. OWNER Steve Rask (Steven & Trace Rask)
MAILING ADDRESS 353 LSF Unit 15
Spring Creek, NV 89815

ADDRESS AT WELL LOCATION McClellan AV
Lot 1, Blk 18
Subdivision Name: Lucky Nugget County: Elko

2. LOCATION NW ¼ SE ¼ Sec 15 T 32 N/S R 55 E
PERMIT/WAIVER No. 027-018-001
Issued by Water Resources Parcel No.

Latitude W 115° 45.765
Longitude N 40° 39.417
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	15	15
alluvial ~~sand~~ gravel				
Gravel + Sand		15	60	45
Clay		60	75	15
	80	75	125	50

Date started: 5.14, 20 12
Date completed: 5.12, 20 12

RECEIVED 2012 JUN -8 AM 10:48 STATE ENGINEERS OFFICE

9. WELL CONSTRUCTION
Depth Drilled 125 Feet Depth Cased 125 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	125	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	125

Perforations:
Type of perforation millslot
Size of perforation 3/16 x 3
From 115 feet to 125 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 15 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 60 to 125 ☐ Pumped ☒ Poured
Type: pea gravel
Bentonite Chips: ☒ Yes ☐ No 15 to 60 ☐ Pumped ☒ Poured
Type: 3/8 chips

7. Water Level
Static water level: 60 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50		5

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Alternative Drilling Co. LLC (Contractor)
Address P.O. Box 281166 (Contractor)
Lamoille, NV 89828
Nevada contractor's license number issued by the State Contractor's Board 73955
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2465
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 5-18-12

(Rev. 05-06) USE ADDITIONAL SHEETS IF NECESSARY

40.657025°N
115.761852°W NAD27

(NSPO 3-08) (O) 627