STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116509
Permit No.
Basin 179

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK (+ Connie)

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68005

1. OWNER Charles Odgers
MAILING ADDRESS PO Box 150235
Ely, NV 89315

ADDRESS AT WELL LOCATION Lot P-2
Ely, NV
Subdivision Name: County: White Pine

2. LOCATION NE ¼ NW ¼ Sec 7 T 17 N/S R 64 E
PERMIT/WAIVER No. R3D-2012-14 (Issued by Water Resources) 010-310-24 (Parcel No.)

Latitude 39° 21.710 Longitude 114° 48.929
UTM E N
☐ NAD 27 ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil - Clay, Silt, Sand		0	10	10
Sand, Gravel, Cobbles	X	10	60	50
Sand, Boulders (Hard)	X	60	80	20
Sand, Gravel, Cobbles	X	80	160	80

RECEIVED 2012 AUG -3 AM 11:19 STATE ENGINEERS OFFICE

Date started: July 27, 2012
Date completed: July 30, 2012

9. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12	Inches	0	Feet	160	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	22.36	.250	+2	40
8.625		(SDR17)	40	160

Perforations:
Type of perforation Mill
Size of perforation 1/8 x 2 1/2 x 8 row
From 80 feet to 100 feet
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☒ Cement Grout 0 to 50 ☒ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 160 ☐ Pumped ☒ Poured
Type: Pea Gravel
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

7. Water Level
Static water level: 25 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
500		30 min.
39.361895°N		NAD27
114.814632°W		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Gardner Brothers Drilling (Contractor)
Address PO Box 965 (Contractor)
Enterprise, UT 84725
Nevada contractor's license number issued by the State Contractor's Board 0068459
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2468
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date July 30, 2012

(Rev. 06-06)
USE ADDITIONAL SHEETS IF NECESSARY