

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68392

1. OWNER Matthew & Brittany Carter ADDRESS AT WELL LOCATION 420 S 100 E  
 MAILING ADDRESS P.O. Box 118 Lund, NV 89317 Wgs 84 N 38° 51.026'  
W 115° 00.283' LOT 11, parcel 3

2. LOCATION SE 1/4 SE 1/4 Sec. 33 T. 12 N/S R 62 E White Pine County  
 PERMIT NO. NA Issued by Water Resources Parcel No. 006-035-11 Subdivision Name Lund township

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top soil		0	1	
gravel clay mix		1	44	
clay gravel mix		46	51	
cemented gravel	water	51	75	1
clay		75	77	
gravel cement		77	83	
clay		83	85	
gravel	water	85	88	3
clay		88	90	
gravel	water	90	115	

38.850489°N NAD 27  
 115.003868°W

8. WELL CONSTRUCTION  
 Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	Feet	To	Feet
<u>10</u>	<u>0</u>	<u>55</u>		
<u>8</u>	<u>55</u>	<u>107</u>		
<u>6</u>	<u>107</u>	<u>115</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>129</u>	<u>.188</u>	<u>-18"</u>	<u>115'</u>

Perforations:  
 Type perforation mill  
 Size perforation 6 x 2.5" x 6 row

From	feet to	feet
<u>70</u>	<u>110</u>	

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 55  
 Placement Method:  Pumped  Poured  
 Concrete Grout

Gravel Packed:  Yes  No  
 From 55 feet to 105 feet

Date started Dec 13, 2012  
 Date completed July 28, 2013

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>5</u>	<u>1 hr</u>

9. WATER LEVEL  
 Static water level 73 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor  
 Address P.O. Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047224  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Quinn Maynard  
 By driller performing actual drilling on site or contractor  
 Date March 5-13