STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116540
Permit No.
Basin No. 101

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69176
WELL NAME *(If applicable)*:

1. OWNER/CLIENT NAME Steve Felton
MAILING ADDRESS 2130 Bafford Lane
NW Fallon, NV 89406

DETAILED ADDRESS AT WELL LOCATION Curry Rd
Fallon, NV 89406
Subdivision Name: *County:* Churchill

2. PLS LOCATION ~~NE~~ ¼ ~~NE~~ ¼ ¼ 2 Sec 17 N/S 28 E
PERMIT/WAIVER NO. R-725 *Issued by Water Resources* 006-031-06 *Current Parcel No.*

Latitude 39.37240 N UTM E ☐ NAD 27
Longitude 118.80873 W UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☐ Rotary ☐ RVC
☐ Air ☒ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ.	Water Strata	From	To	Thick-ness
Brown Sand			0	8	8
Brown Clay			8	26	18
Brown Sand		X	26	32	6

39.372481 °N NAD 27
118.807745 °W

Date started: 23-Jan , 20 13
Date completed: 25-Jan , 20 13

RECEIVED 2013 FEB 19 AM 11:50 STATE ENGINEER'S OFFICE

9. WELL CONSTRUCTION
Depth Drilled: 32 Feet Depth Cased: 32 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	32	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	12.92	.188	0	20
6.625	4	.316	20	32

PERFORATIONS:
Type of perforation: Saw Cut
Size of perforation: 0.125
From 32 Feet To 28 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	26 to 0			
☒ Neat Cement	20 to 0		☒ Pumped	☐ Poured
☐ Cement Grout	to		☐ Pumped	☐ Poured
☐ Concrete Grout	to		☐ Pumped	☐ Poured
☒ Bentonite Chips	26 to 20		☐ Pumped	☒ Poured
☐ Bentonite Grout	to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:				
☒ Gravel Pack [> 0.2 in.]	32 to 26		☐ Pumped	☐ Poured
☐ Sand Pack [< 0.2 in.]	to		☐ Pumped	☐ Poured
☐ Other, explain:	to		☐ Pumped	☐ Poured

7. WATER QUALITIES
Static water level: 8 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cool ° Fahrenheit
Water Quality: Unknown

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
15		1

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Parsons Drilling, INC
Contractor
Address P.O. Box 1265 Fallon, NV 89406
Contractor
Nevada contractor's license number as issued by the *State Contractor's Board:* 29064
Nevada well driller's license number as issued by the *Nevada Division of Water Resources (on-site driller):* 2307
Signed:
By driller performing actual drilling on site or contractor
Date: 2/3/2013

(Rev. 08-12)

USE ADDITIONAL SHEETS IF NECESSARY