

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 116548  
Permit No. \_\_\_\_\_  
Basin No. 048

PRINT OR TYPE IN BLACK INK ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69678

1. OWNER/CLIENT NAME James Bennett  
MAILING ADDRESS P.O. Box 1461, Carlin, NV 89822

DETAILED ADDRESS AT WELL LOCATION 1032 McClellan Ave.

2. PLG LOCATION NE 1/4 SE 1/4 15 Sec 32 T5S 55 E  
PERMIT/WAIVER NO. 027-017-002

Lucky Nugget #1 Elko  
Latitude W115°45.505 UTM E  NAD 27  
Longitude N40°39.375 UTM N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Deepen: Orig WL# \_\_\_\_\_  
 Replacement: Original well log # \_\_\_\_\_  
 Recondition: Original well log # \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Monitor  
 Mining / Dewater  Com / Ind  Stock  
 Test / Other  Mun / QM  Rec

5. WELL TYPE  
 Auger  Rotary  RVC  
 Air  Mud  Sonic  
 Other

6. LITHOLOGIC LOG

Material Encountered	Lost	Water	From	To	Thick-ness
sand			0	10	10
gravel/sand			10	40	30
sand			40	60	20
gravel/sand		60	60	120	60
		95			

9. WELL CONSTRUCTION

Depth Drilled:	120	Feet	Depth Cased:	120	Feet
From			To		
10 5/8	inches	0	Feet	120	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+2	120

PERFORATIONS:

Type of perforation: mill slot  
Size of perforation: 3/16 x 3  
From 100 Feet To 120 Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet  
From \_\_\_\_\_ Feet To \_\_\_\_\_ Feet

ANNULAR MATERIALS

Sanitary Seal \_\_\_\_\_ to \_\_\_\_\_  
 Neat Cement \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Cement Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Concrete Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Bentonite Chips 20 to 50  Pumped  Poured  
 Bentonite Grout \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 15 %  20 %  Other, explain: \_\_\_\_\_  
 Gravel Pack [ > 0.2 in. ] 50 to 120  Pumped  Poured  
 Sand Pack [ < 0.2 in. ] \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured  
 Other, explain: \_\_\_\_\_ to \_\_\_\_\_  Pumped  Poured

Date started: 14-Feb , 20 13  
15-Feb , 20 13

7. WATER QUANTITIES  
Static water level: 25 Feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: cold ° Fahrenheit  
Water Quality: \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision. This report is true to the best of my knowledge.  
Name Alternative Drilling Co LLC  
Contractor  
Address P.O. Box 281166, Lamoille, NV 89828  
Contractor

8. WELL TEST DATA

Test Method:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input checked="" type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)		Recorded Time (Hours)
100			8
40	656325 °N		NAD27
115	757519 °W		

Nevada contractor's license number as issued by the State Contractor's Board: 73955  
Nevada well driller's license number as issued by the \_\_\_\_\_ 2465  
Signed: Eugene Rosewell  
3-3-13