STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116554
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69915

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 872 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NE ¼ NW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-011
Issued by Water Resources
Parcel No.

Latitude
Longitude
UTM E 11T 0602147 [X] NAD 27
N 4516372 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL w/ SOME GRAVEL		0	20	20
SAND & GRAVEL w/ SOME				
BROWN CLAY		20	40	20
TAN CLAY		40	80	40
GREY CLAY	X	80	240	160
FINE GRAVEL	XX	240	280	40
1ST WATER	X	230		
2ND WATER	XX	260		

RECEIVED 2013 MAR -8 AM 11:11 STATE ENGINEERS OFFICE

Date started: 21-Feb, 20 13
Date completed: 22-Feb, 20 13

7. Water Level
Static water level: 90 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 70 °F
Quality:

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 275'	80		1 1/2 HOUR
AT 200'	60		
AT 160'	40		
AT 140'	25		
AT 120'	10		

9. WELL CONSTRUCTION
Depth Drilled 280 Feet Depth Cased 278 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	280	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	278

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 258 feet to 278 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 25 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 278 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 25 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed Dale E. Vedesc (By driller performing actual drilling on site or contractor)
Date 2/22/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

40.793899°N
115.789242°W NAD27