

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116555
Permit No. _____
Basin 419

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69916

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 1191 DRY CREEK TRAIL

Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SE 1/4 NW 1/4 Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-029
Issued by Water Resources Parcel No. _____

Latitude UTM E 11T 0602257 NAD 27
Longitude N 4515875 NAD 83/WGS 84

3. WORKED PERFORMED
 New Well Replace Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thick-ness
TOP SOIL STRIPPED				
GRAVEL w/ BOULDERS		0	20	20
REDISH BROWN GRAVEL w/ CLAY		20	40	20
TAN CLAY w/ OCCASIONAL LENS OF GRAVEL	X	40	300	260
COURSE GRAVEL	XX	300	318	18
1ST WATER	X	180		
2ND WATER	XX	300		

9. WELL CONSTRUCTION				
Depth Drilled	318	Feet	Depth Cased	318
HOLE DIAMETER (BIT SIZE)				
From	To	From	To	
10 5/8	Inches	0	Feet	318
	Inches		Feet	
	Inches		Feet	

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	318

Date started: 12-Feb , 20 13
Date completed: 14-Feb , 20 13

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 298 feet to 318 feet
From _____ feet to _____ feet

Annular Seal: Yes No
 Neat Cement 4 to 25 Pumped Poured
 Cement Grout _____ to _____ Pumped Poured
 Concrete Grout _____ to _____ Pumped Poured
 ≥30% Bentonite Grout _____ to _____ Pumped Poured

Gravel Pack: Yes No 55 to 318 Pumped Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: Yes No 25 to 55 Pumped Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 96 feet below land surface
Artesian Flow: _____ G.P.M. _____ P.S.I.
Water Temperature: 62 °F
Quality: _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC.
Contractor
Address P. O. BOX 850
Contractor
ELKO, NV 89803
Nevada contractor's license number
issued by the State Contractor's Board 020582
Nevada driller's license number issued by the
Division of Water Resources, the on-site driller 166
Signed Dale C. Hederson
By driller performing actual drilling on site or contractor
Date 2/15/2013

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
AT 310'	40		3 HOURS
AT 220'	20		