STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116556
Permit No.
Basin 649

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69917

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 1169 DRY CREEK TRAIL
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION SE ¼ NW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-028
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602194 [X] NAD 27
N 4515941 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL w/ GRAVEL & ROCKS		0	10	10
REDISH BROWN GRAVEL &				
ROCKS w/ SOME CLAY		10	40	30
BROWN CLAY & GRAVEL		40	60	20
TAN CLAY w/ SOME GRAVEL		60	90	30
GREY CLAY w/ GRAVEL LENS	X	90	240	150
TAN CLAY & GRAVEL	X	240	280	40
FINE GRAVEL	XX	280	300	20
1ST WATER X	180			
2ND WATER X	240			
3RD WATER XX	280			

Date started: 15-Feb , 20 13
Date completed: 18-Feb , 20 13

9. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 298 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8"	Inches	0	Feet	300	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	298

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 278 feet to 298 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 25 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 298 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 25 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 109 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 71 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 290'	100		1 1/2 HOUR
AT 200'	50		
AT 160'	30		
AT 140'	15		

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1166
Signed (By driller performing actual drilling on site or contractor)
Date 2/19/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

40.790012 °N
115.788755 °W NAD27