STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116557
Permit No.
Basin 049

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69918

1. OWNER ARNOLD BECK CONSTRUCTION INC
MAILING ADDRESS 247 GREENCREST DR
SPRING CREEK, NV 89815

ADDRESS AT WELL LOCATION 793 DRY CREEK TRAIL, Spring creek
Subdivision Name: SPECIAL LANDS County: ELKO

2. LOCATION NW ¼ NW ¼ Sec 33 T 34N N/S R 55 E
PERMIT/WAIVER No. 006-09Q-005
Issued by Water Resources Parcel No.

Latitude
Longitude
UTM E 11T 0602117 [X] NAD 27
N 4516480 [ ] NAD 83/WGS 84

3. WORKED PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAVEL w/ BOULDERS		0	25	25
FINE GRAVEL w/ SAND & CLAY		25	35	10
TAN CLAY & SAND		35	75	40
GREY BLACK CLAY		75	215	140
GREY VOLCANIC TUFT	X	215	240	25
GREY BROWN TUFT w/ FINE GRAVEL	XX	240	260	20
1ST WATER X		215		
2ND WATER XX		250		

Date started: 5-Feb, 20 13
Date completed: 7-Feb, 20 13

9. WELL CONSTRUCTION
Depth Drilled 260 Feet Depth Cased 260 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	13	.188	+2	260

Perforations:
Type of perforation PLASMA CUT
Size of perforation 3/16" X 4", 7 ROWS
From 240 feet to 260 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: [X] Yes [ ] No
[X] Neat Cement 4 to 25 [ ] Pumped [X] Poured
[ ] Cement Grout to [ ] Pumped [ ] Poured
[ ] Concrete Grout to [ ] Pumped [ ] Poured
[ ] ≥30% Bentonite Grout to [ ] Pumped [ ] Poured

Gravel Pack: [X] Yes [ ] No 55 to 260 [ ] Pumped [X] Poured
Type: 3/8" WASHED PEA GRAVEL
Bentonite Chips: [X] Yes [ ] No 25 to 55 [ ] Pumped [X] Poured
Type: 3/8" BENTONITE CHIPS

7. Water Level
Static water level: 86 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: 68 °F
Quality: GOOD

8. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AT 250'	75		1 1/2 HOURS
AT 180'	50		1/4 HOUR
AT 120'	25		1/4 HOUR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P. O. BOX 850 (Contractor)
ELKO, NV 89803
Nevada contractor's license number issued by the *State Contractor's Board* 020582
Nevada driller's license number issued by the Division of Water Resources, the *on-site driller* 1653
Signed (By driller performing actual drilling on site or contractor)
Date 2/8/2013

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

40.794876 °N
115.789580 °W NAD 27

2013 FEB 19 PM 1:13 STATE ENGINEERS OFFICE