

NDER PERMIT:

NEV 0091029

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116561
Permit No.
Basin 061

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 69994

1. OWNER Barrick Goldstrike Mines Inc. ADDRESS AT WELL LOCATION Barrick Goldstrike Mine Site
MAILING ADDRESS PO Box 29 "Well # MW-11-01"
Elko Nevada 89803

2. LOCATION SE 1/4 NE 1/4 Sec 17 T 36N N/S R 50 E Latitude UTM E 555720 NAD 27
PERMIT/WAIVER No. N/A N/A Longitude N 4538800 NAD 83/WGS 84
Issued by Water Resources Parcel No. Subdivision Name: N/A North Block Project County: Eureka

3. WORKED PERFORMED: [X] New Well, [] Replace, [] Recondition, [] Deepen, [] Other...
4. PROPOSED USE: [] Domestic, [] Irrigation, [] Test, [] Municipal/Industrial, [X] Monitor, [] Stock
5. WELL TYPE: [] Cable, [] Rotary, [X] RVC, [] Air, [] Other...

6. LITHOLOGIC LOG table with columns: Material, Water Strata, From, To, Thickness. Includes entries for Clayey sand, Silty fine sand, Alluvium, and Hole abandoned from 110'-112'.

B. WELL CONSTRUCTION table with columns: Depth Drilled, Depth Cased, Hole Diameter (Bit Size), and Casing Schedule.

Perforations: Type of perforation Slotted, Size of perforation 0.02, From 90 feet to 110 feet.
Surface Seal: [X] Yes, [] No, Depth of Seal 50', Placement Method: [] Pumped, [X] Poured, Seal Type: [X] Neat Cement, [] Cement Grout, [] Concrete Grout.
Gravel Packed: [X] Yes, [] No, From 88 feet to 110 feet.

9. WATER LEVEL: Static water level 37 feet below land surface, Artesian flow None, G.P.M. N/A, P.S.I. Water temperature Cold, Quality Fair.

10. DRILLER'S CERTIFICATION: This well was drilled under my supervision and the report is true to the best of my knowledge. Name National EWP, Address 580 West Silver Street, Elko Nevada 89801. Nevada contractor's license number 00075355, Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2453. Signed [Signature], Date 2/8/2013.

Date started Feb. 4th, 20 13
Date completed Feb 5th, 20 13

7. WELL TEST DATA table with columns: TEST METHOD (Bailer, Pump, Air Lift), G.P.M., Draw Down (Feet Below Static), Time (Hours). Includes entry for 109' depth, N/A G.P.M., 73' draw down, 1 Hour time.

(Rev. 06/10) 41. 000392 - N
116. 337483 - W NAD27

USE ADDITIONAL SHEETS IF NECESSARY