STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116581
Permit No.
Basin 069

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 66776

1. OWNER Gary ~~Frakacs~~ + Barbara Takacs
MAILING ADDRESS 5900 Mountain View
Winnemucca NV. 89445

ADDRESS AT WELL LOCATION 5900 Mountain View
Winnemucca NV. 89445
Subdivision Name: Paradise Ranchos County: Humboldt

2. LOCATION NW NW ¼ Sec 12 T 37N/S R 38 E
PERMIT/WAIVER No. 006-131-03
Issued by Water Resources Parcel No.

Latitude N41°16.690
Longitude W117°39.410
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand clay	Yes	100	120	20
Hard brown clay	no	120	135	15
Gravel clay sand	yes	135	145	10
Gravel Sand clay	yes	145	175	30
Hard brown clay	No	175	185	10
Sand Clay Gravel	yes	185	200	15

* original well log being deepened - unknown

Date started: 8-25, 20 12
Date completed: 8-29, 20 12

7. Water Level
Static water level: 77 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air lift	35	NA	6
Pump	24	0	1

9. WELL CONSTRUCTION
Depth Drilled 100 to 200 Feet Depth Cased 0 to 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 7/8	Inches	100 Feet	200 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	PVC	Sched 40	20	200
6 5/8	Steel	.188	0	20
8	Steel	Unknown	0	100

Perforations:
Type of perforation Slot
Size of perforation .20
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No

☒ Neat Cement	0 to 50	☐ Pumped	☒ Poured
☐ Cement Grout	to	☐ Pumped	☐ Poured
☐ Concrete Grout	to	☐ Pumped	☐ Poured
☐ ≥30% Bentonite Grout	to	☐ Pumped	☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 200 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed (By driller performing actual drilling on-site or contractor)
Date 8-29-12

USE ADDITIONAL SHEETS IF NECESSARY

41.278167 °N
117.656833 °W
NAD27

(Rev. 05-08)
(NSPO 3-08)
(O) 627