

STATE OF NEVADA  
DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
Log No. 116608  
Permit No. \_\_\_\_\_  
Basin 105

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 67787

1. OWNER CESAR PACHECO  
MAILING ADDRESS 1680 STEPHANIE WAY  
MINDEN, NV 89423

ADDRESS AT WELL LOCATION 1680 STEPHANIE WAY  
MINDEN, NV 89423

Subdivision Name: \_\_\_\_\_ County: Douglas

2. LOCATION SE 1/4 SW 1/4 Sec 26 T 14N N/S R 20 E  
PERMIT/WAIVER No. 1420-26-401-039  
Issued by Water Resources Parcel No. \_\_\_\_\_

Latitude 39.04137°N UTM E  NAD 27  
Longitude 119.70783°W N  NAD 83/WGS 84

3. WORKED PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other  MUD

6. LITHOLOGIC LOG				
Material	Water Strata	From	To	Thickness
OVER BURDEN		0	6	6
BROWN SANDS		6	167	161
GRAY CLAY		167	252	85
DG SANDS		252	275	23
GRAY CLAY		275	310	35
FRACTURED DG SANDS	XX	310	380	70
* See corresponding plugging NOI # 67801				

9. WELL CONSTRUCTION				
Depth Drilled	380	Feet	Depth Cased	380
HOLE DIAMETER (BIT SIZE)				
	From	To		
10 5/8	0	380	Feet	Feet
			Feet	Feet
			Feet	Feet

CASING SCHEDULE				
Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	20
6 5/8	4.26	.216	20	380
SDR 21				

Perforations:				
Type of perforation	SAW CUT			
Size of perforation	3 X 3/32			
From 340	feet to	380	feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	
From	feet to		feet	

Annular Seal:  Yes  No

Neat Cement to \_\_\_\_\_  Pumped  Poured  
 Cement Grout 0 to 100  Pumped  Poured  
 Concrete Grout to \_\_\_\_\_  Pumped  Poured  
 ≥30% Bentonite Grout to \_\_\_\_\_  Pumped  Poured

Gravel Pack:  Yes  No 100 to 380  Pumped  Poured  
 Type: \_\_\_\_\_ PEAT GRAVEL  
 Bentonite Chips:  Yes  No to \_\_\_\_\_  Pumped  Poured  
 Type: \_\_\_\_\_

7. Water Level  
Static water level: 180 feet below land surface  
Artesian Flow: \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water Temperature: COLD °F  
Quality: GOOD

8. WELL TEST DATA			
TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	25	80	3 HRS

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name CAPITAL CITY WELL DRILLING AND PUMP SERVICE INC.  
Contractor  
Address 20 KIT KAT DRIVE  
Contractor  
CARSON CITY, NV 89706  
Nevada contractor's license number \_\_\_\_\_  
issued by the State Contractor's Board 0055548  
Nevada driller's license number issued by the \_\_\_\_\_  
Division of Water Resources, the on-site driller 1905  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 06/29/2012

Rev. 05-09  
39.041461°N  
119.706820°W NAD27

USE ADDITIONAL SHEETS IF NECESSARY