STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116634
Permit No.
Basin 212

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 36683

1. OWNER Mixed Income LLC
MAILING ADDRESS 2009 Bita, LV, NV 89106
ADDRESS AT WELL LOCATION 65 Windmill None
Subdivision Name: County: CLARK DSB

2. LOCATION NW ¼ NW ¼ Sec 16 T 22 N/S R 61 E
PERMIT/WAIVER No. 177-16-101026
Issued by Water Resources Parcel No.
Latitude N 36-02-31.2 Longitude W 115-10-07.4
UTM E N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Other ABANDON

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ABANDON WELL 8" DIA				
125 ft Deep - STEEL CASING				
STATIC WATER 128 ft				
RUN BIT to BOTTOM - WELL CLEAR				
PERFERATE FROM BOTTOM UP TO 70 ft.				
FILL WITH NEAT CEMENT FROM BOTTOM UP WITH TREMIE PIPE TO SURFACE.				
Depth of Well 150 ft.				
Fill with Neat Cement from Bottom up to Surface				
36.042 NAD27				
-115.1687222				

Date started: 2-22-13, 20
Date completed: 2-23-13, 20

7. Water Level
Static water level: 128 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: °F
Quality:

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

DCNR/DWR/SNBO RECEIVED
FEB 22 2013

9. WELL CONSTRUCTION
Depth Drilled Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type of perforation
Size of perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☐ Yes ☐ No
☐ Neat Cement to ☐ Pumped ☐ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured
Gravel Pack: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:
Bentonite Chips: ☐ Yes ☐ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) DERNON H. DIMICK
Address (Contractor) 13040 HORSE DR - LV. NV 89166
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick
(By driller performing actual drilling on-site or contractor)
Date 2-23-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08)

(date log rec'd prior to date complete -DSB)

(O) 627