STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116677
Permit No.
Basin 070

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68498

1. OWNER Rick Schofield
MAILING ADDRESS 4270 Warmouth
Winnemucca NV

ADDRESS AT WELL LOCATION Commercial St.
Winnemucca NV.
Subdivision Name: Sonoma Ranchos #2 County: Humboldt

2. LOCATION NW¼ SW¼ Sec 17 T 35 N S R 37 E
PERMIT/WAIVER No. 013-224-07
Issued by Water Resources Parcel No.

Latitude N40°54.361 UTM E
Longitude W117°50.851 N
☒ NAD 27 ☐ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Hard Brown Clay	NO	0	50	50
Clay Gravel Sand	yes	50	80	30
Gravel Sand Clay	yes	80	140	60

NAD27
40.906017°N
117.847517°W

Date started: 4-24, 20 13
Date completed: 4-26, 20 13

7. Water Level
Static water level: 53 feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: Cold °F
Quality: Clear

8. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
40	NA	4½

9. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10⅞	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6⅝	Steel	0188	0	20
6⅝	PVC	Sched 40	20	140

Perforations:
Type of perforation Slot
Size of perforation .20
From 100 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Annular Seal: ☒ Yes ☐ No
☒ Neat Cement 0 to 50 ☐ Pumped ☒ Poured
☐ Cement Grout to ☐ Pumped ☐ Poured
☐ Concrete Grout to ☐ Pumped ☐ Poured
☐ ≥30% Bentonite Grout to ☐ Pumped ☐ Poured

Gravel Pack: ☒ Yes ☐ No 50 to 140 ☐ Pumped ☒ Poured
Type:
Bentonite Chips: ☐ Yes ☒ No to ☐ Pumped ☐ Poured
Type:

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allied Drilling Inc. (Contractor)
Address 5140 Jungo Rd. (Contractor)
Winnemucca NV. 89445
Nevada contractor's license number issued by the State Contractor's Board 76778
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1563
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 5-8-13

(Rev. 05-06)

USE ADDITIONAL SHEETS IF NECESSARY

(NSPO 3-08) (O) 627