STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
Log No. 116693
Permit No.
Basin No. 049

PRINT OR TYPE IN BLACK INK ONLY
DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 68784

1. OWNER/CLIENT NAME Richard Scott Barton
MAILING ADDRESS 588 S Richmond Av
Carson City, NV 89703

DETAILED ADDRESS AT WELL LOCATION 7th St, Lot 8, Block 31
Meadow Valley Ranchos — Elko

2. PLS LOCATION NW ¼ SE ¼ SE ¼ 33 Sec. 36 N/S 56 E
PERMIT/WAIVER NO. 034-031-008
Latitude N40*57.626 UTM E ☐ NAD 27
Longitude W115*39.938 UTM N ☒ NAD 83/WGS 84

3. WORKED PERFORMED
☒ New Well ☐ Deepen: Orig WL#
☐ Replacement: Original well log #
☐ Recondition: Original well log #

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Monitor
☐ Mining / Dewater ☐ Com / Ind ☐ Stock
☐ Test / Other ☐ Mun / QM ☐ Rec

5. WELL TYPE
☐ Auger ☒ Rotary ☐ RVC
☒ Air ☐ Mud ☐ Sonic
☐ Other

6. LITHOLOGIC LOG

Material Encountered	Lost Circ	Water Static	From	To	Thickness
top soil			0	2	2
sand & gravel			2	8	6
silt stone			8	200	192
silt stone & gravel mix		240	200	260	60

RECEIVED 2013 MAY 22 AM 11:0 STATE ENGINEERS OFF

NAD27
40,960514° N
115,664733° W

Date started: 10-May, 20 13
13-May, 20 13

7. WATER QUALITIES
Static water level: 180 Feet below land surface
Artesian Flow: G.P.M. P.S.I.
Water Temperature: cold ° Fahrenheit
Water Quality:

8. WELL TEST DATA
Test Method: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Recorded Time (Hours)
20		6

9. WELL CONSTRUCTION
Depth Drilled: 260 Feet Depth Cased: 260 Feet

		From		To	
10 5/8	Inches	0	Feet	260	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+18	260

PERFORATIONS:
Type of perforation: mill slot
Size of perforation: 3/16 x 3
From 240 Feet To 260 Feet
From Feet To Feet
From Feet To Feet

ANNULAR MATERIALS

☒ Sanitary Seal	5	to	100		
☒ Neat Cement	5	to	25	☐ Pumped	☒ Poured
☐ Cement Grout		to		☐ Pumped	☐ Poured
☐ Concrete Grout		to		☐ Pumped	☐ Poured
☒ Bentonite Chips	25	to	100	☐ Pumped	☒ Poured
☐ Bentonite Grout		to		☐ Pumped	☐ Poured
☐ 15 % ☐ 20 % ☐ Other, explain:					
☒ Gravel Pack [> 0.2 in.]	100	to	260	☐ Pumped	☒ Poured
☐ Sand Pack [< 0.2 in.]		to		☐ Pumped	☐ Poured
☐ Other, explain:		to		☐ Pumped	☐ Poured

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision. This report is true to the best of my knowledge.
Name Alternative Drilling Co LLC (Contractor)
Address P.O. Box 281166, Lamoille, NV 89828 (Contractor)
Nevada contractor's license number as issued by the *State Contractor's Board:* 73955
Nevada well driller's license number as issued by the 1689
Signed: (Driller performing actual drilling on site or contractor)
Date: 5-15-13

(Rev. 08-12)
USE ADDITIONAL SHEETS IF NECESSARY